



**Office of the District Fire Officer,
Karnataka Fire & Emergency Services,
Mahadevapura Fire Station
Garudachara Palya, Bengaluru-560 048.**



No. 34/DFO/MFS/RFSCR/2026

Dated: 15-04-2026.

ANNEXURE – 2

Group - B Educational Building

NBC-2016, Part-4, Table 7(11) 3.1.3 Group B Educational Buildings Sub Division B1 & B2.

(These condition are indicative and not exclusive all relevant provisions related to fire and life safety of NBC-2016 are mandatory).

To,
The Authorized Signatory,
M/s. BNR Education Trust,
U-Dise Code:-29214101384
Anekam School,
Survey NO:1/2,
Gullakaipura Village, Muthsandra Road,
Bangalore Rural-560087.

Sir,

Sub : Issue of "Renewal Fire Safety Compliance Report" with respect to fire prevention, firefighting and evacuation measures maintained at "M/s. BNR Education Trust, "Anekam School" Survey NO:1/2, Gullakaipura Village, Muthsandra Road, Bangalore Rural-560087" .reg.

Ref : 1) FSR No.15/DFO/MFS/FSR/2025, Dt: 10-02-2025.
2) FSCR No.15/DFO/MFS/FSCR/2025, Dated: 10-02-2025.
3) Inspection report. No.34/DFO/MFS/RFSCR/2026, Dated:06-04-2026.
4) Your request letter dated: 04-04-2026.

<<<>>>

With reference to the above cited subject, as per ref(1), a Conditional Fire Safety recommendation was issued to the premises of at "M/s. BNR Education Trust, "Anekam School" Survey NO:1/2, Gullakaipura Village, Muthsandra Road, Bangalore Rural-560087." with a condition to fulfill the recommendations and compliance the same within 3 months.

With reference cited (2) above, "Fire Safety Compliance Report" was issued and With reference cited (3) above, "Renewal Fire Safety Compliance Report" was issued for the above building. And Now the management of "M/s. BNR Education Trust" has requested for the Renewal of fire safety compliance Report from our department. In this regard the above addressed educational building was re-inspected by me on 07-04-2026 for Renewing the fire safety compliance report and as per ref(3) submitted the report to this office.



Under the above circumstance the Karnataka Fire & Emergency Services Department is issuing the "Renewal Fire Safety Compliance Report" to "M/s. BNR Education Trust, "Anekam School" Survey NO:1/2, Gullakaipura Village, Muthsandra Road, Bangalore Rural-560087." Subject to proper maintenance of firefighting installations in the good working conditions and arrange for 40% of staffs/ employees training within 03 months from the date of issue of this report.

This fire Safety Compliance Report is issued from the Fire Prevention and Fire Fighting Point of view Karnataka State Fire & Emergency Services Department is not responsible for the ownership of the land, its location and other disputes, which may arise in due course.

in case the fire prevention and firefighting measures installed in the building as per the recommendation of the department are not maintained in good working condition, if the evacuation measures are not properly followed and if any additional construction work is taken up in the Building/premises, this fire safety Compliance Report deemed to be cancelled and necessary legal action will be initiated against the developer/management/tenant and also separate NOC has to be obtained from the department for the storage of Chemicals, Solvents, Petroleum products (Diesel, Petrol), LPG etc in the premises/ building.

"This Fire safety compliance Report is valid till Dt: 15-04-2031 and it is renewable without fail".

Yours faithfully,


District Fire Officer
Karnataka Fire & Emergency Services
Mahadevapura Fire Station,
Bengaluru - 560048